

# Option Y0038 for the Model 751 Field Signal Indicator

## SPECIAL CONSIDERATIONS FOR THE MODEL 751 ORDERED WITH THE Y0038 OPTION

### Important

Rosemount Inc. has verified that the Model 751 Field Signal Indicator ordered with an analog meter (option codes M1, M2, M3, or M6) will operate at temperatures down to  $-60^{\circ}\text{F}$  ( $-51^{\circ}\text{C}$ ). Rosemount Inc. does not guarantee that the output will remain within the published accuracy specification when operating outside of the meter's normal ambient temperature range.

Rosemount Inc. has verified that the Model 751 Field Signal Indicator ordered with a LCD meter (option codes M4, M7, M8, or M9) will not be damaged and will remain intact when operating at temperatures down to  $-60^{\circ}\text{F}$  ( $-51^{\circ}\text{C}$ ).

### WARNING

Any hazardous location approvals ordered with this transmitter are void if the transmitter is operating outside of the ambient temperature limits specified for that certification.

Approved ambient temperature limits are specified in the following locations:

- Enclosure approval label
- Hazardous locations installation drawings
- "Approvals" appendix of the reference manual

# Model 751 Field Signal Indicator

---

*Rosemount and the Rosemount logotype are registered trademarks of Rosemount Inc.  
All other marks are the property of their respective owners.*

## **Emerson Process Management**

### **Rosemount Inc.**

8200 Market Boulevard  
Chanhassen, MN 55317 USA  
T (U.S.) 1-800-999-9307  
T (International) (952) 906-8888  
F (952) 949-7001

[www.rosemount.com](http://www.rosemount.com)

